

MASONS Barricade PLUS Window Tape over flashing onto MASONS Barricade Building Wrap extended 20mm each side of opening

14gx100mm Bugle Head Type 17 Screws embedded 10mm max. into panel. Min 50mm from edge.

MASONS AAC render & coating system
50mm AAC ENVIRO Panel

MASONS Barricade PLUS Window Tape

Turn up ends of head flashing 20mm

Approved foam tape adhered to top of window flange

Aluminium Window Head Moulding Flashing with 15° Fall to be installed by builder

MASONS Barricade Building Wrap

Discontinuous horizontal 50x20mm EPS or H3.2 timber battens on a 15° slope and no longer than 100mm as required for fixing.

Timber Framing

35mm Min Cover

Packers

5mm Nominal

Note: MASONS Sill and base shoe flashings must be primed with Plasta Seal and coated with MASONS meshing render

OPENING FLASHING Window Head

Detail 18
Scale 1:2

MASONS Barricade Building Wrap

MASONS Barricade PLUS Window Tape over flashing onto MASONS Barricade Building Wrap extended 20mm each side of opening

Turn up ends of head moulding 20mm

BOSTIK Safe Seal flexible sealant

Aluminium Window Head Moulding Flashing with 15° Fall to be installed by builder

Approved foam tape adhered to top of window flange

MASONS Barricade PLUS Window Tape

Note: Cladding not shown

Packers

Water resistant air seal

OPENING FLASHING - 3D View

**MASONS ENVIRO AAC ON 20mm CAVITY
TIMBER FRAME**

Detail 19 NTS