

# Emission Test Certificate

Wednesday, December 4, 2013

Supplier: Armstrong World Industries (29-39 Mills Road, Braeside, VIC, 3195)

Sample Description: Luxury Vinyl Tile/Plank

Date Tested: October 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: EN 13419 (2003-01) “Building Products - Determination of The Emission Of Volatile Organic Compounds - Part 1: Emission Test Chamber Method”

Emission Data:

<b>Specification</b>  <b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>Luxury Vinyl Tile/Plank</b>
<b>Total Volatile Organic Compound Specific Area Emission Rate &lt;0.5 mg/m<sup>2</sup>/hr</b>	Total Volatile Organic Compound Emission Rate: 0.074 mg/m <sup>2</sup> /hr  Total Volatile Organic Compound Concentration: 0.042 mg/m <sup>3</sup> *  (28 day exposure)

\* Based on the standard room model



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

**CV131016**