



CERTIFICATE



0370-CPR-3974

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

PEDESTRIAN DOORSETS, INDUSTRIAL, COMMERCIAL, GARAGE DOORS AND OPENABLE WINDOWS. PRODUCT STANDARD, PERFORMANCE CHARACTERISTICS AS DESCRIBED IN EN 13241:2003+A2:2016.

FIRE RESISTING AND/OR SMOKE CONTROL CHARACTERISTICS

COMMERCIAL NAME: FIRE CURTAIN FM1 PRODUCT RANGE: FIRE CURTAIN EW

Place on the market under the name of:

COLT INTERNATIONAL LICESING Ltd.

UNIT 12, THE BRIARS, WATERBERRY DRIVE, WATERLOOVILE HAMPSHIRE PO7 7YH, UNITED KINGDOM

And produced in the manufacturing plant:

COLT INTERNATIONAL GmbH.

BRIENER STRASSE 186 47533 KLEVE, GERMANY

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 16034:2014

under system 1 are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 7th May 2020 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is modified on 15th May 2020.

The monitoring assessment will be done before 31st May 2021

Bellaterra, 15th May 2020

√Arplus[⊕] LGAI Technological Center, S.A.

Xavier Ruiz Peña

Managing Director, Product Conformity B.U.

This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate into our website at: https://apps.applus.com/microsites/microsites/FECIP/login



LGAI Technological Center, S.A. (APPLUS) Campus UAB s/n – Ronda de la Font del Carme, s/n E - 08193 Bellaterra (Barcelona) T +34 93 567 20 00 www.appluslaboratories.com



Technical Annex Ed. 1 07/05/2020

0370-CPR-3974

CERTIFIED PERFORMANCE

EN 16034:2014		
ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Resistance to fire (for fire compartmentation uses)	4.1	EW 30
Smoke control (only for applications where limitation of smoke spread is required)	4.2	NA
Ability to release	4.3	RELEASED
Self-closing (only for self-closing fire resistant and/or smoke control doorsets and /or openable windows)	4.4	C1
Durability of ability to release	4.5.1	NA
Durability of self-closing (only for self- closing fire resistant and/or smoke control doorsets and/or	4.5.2.1	1
openable windows) - against degradation (cycling testing) - against ageing (corrosion)	4.5.2.2	NA

PASS; NPD = No Performance Determined; NA = Not Applicable