



# Infrastructure Technologies

Gate 5, 2 Normanby Road Clayton VIC 3168, Australia

Telephone: 61 3 9545 2777 Web: <http://www.csiro.au>

Registered Testing Authority - CSIRO

22 May 2018

Our Ref. EN13 / 2469 03/0212

## TEST REPORT No. 8089.1

Requested by: Armstrong Flooring Pty Ltd  
29-39 Mills Road  
Braeside  
VIC 3195  
on (date): 14 May 2018  
Manufacturer: Armstrong Flooring  
Product Desc.: Accolade Foothold 1 Vinyl Flooring

Sampling details:  
Where: Delivered  
Date: 14 May 2018  
By whom: Courier  
How (methods): N/A

The results reported relate only to the sample(s) tested and the information received. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. CSIRO cannot accept responsibility for deviations in the manufactured quality and performance of the product. While CSIRO takes care in preparing the reports it provides to clients, it does not warrant that the information in this particular report will be free of errors or omissions or that it will be suitable for the client's purposes. CSIRO will not be responsible for the results of any actions taken by the client or any other person on the basis of the information contained in the report or any opinions expressed in it. The reproduction of this test report is only authorised in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction.

This test report consists of 4 pages

### SUMMARY OF SLIP RESISTANCE TESTS PERFORMED:

		Result	Class
AS 4586:2013	Slip resistance classification of new pedestrian surface materials Appendix C: WET-BAREFOOT INCLINING PLATFORM TEST METHOD Mean angle of inclination:	19°	B

In order to interpret the classifications, please refer to Standards Australia Handbook 198, An Introductory Guide to the Slip Resistance of Pedestrian Surface Materials, which recommends minimum classifications for a wide variety of locations.

It is important to realise that test results obtained on unused factory-fresh samples may not be directly applicable in service, where proprietary surface coatings, contamination, wear and subsequent cleaning all influence the behaviour of the pedestrian surface.



## **Infrastructure Technologies**

Gate 5, 2 Normanby Road Clayton VIC 3168, Australia

Telephone: 61 3 9545 2777 Web: <http://www.csiro.au>

---

REPORT NO: 8089.1  
ISSUE DATE: 22 May 2018  
MANUFACTURER: Armstrong Flooring  
PRODUCT DESC: Accolade Foothold 1 Vinyl Flooring

---

Page 2 of 4

PHOTOS:





REPORT NO: 8089.1  
ISSUE DATE: 22 May 2018  
MANUFACTURER: Armstrong Flooring  
PRODUCT DESC: Accolade Foothold 1 Vinyl Flooring

Page 3 of 4

---

**SLIP RESISTANCE CLASSIFICATION OF NEW PEDESTRIAN SURFACE MATERIALS**

**WET-BAREFOOT INCLINING PLATFORM TEST METHOD**

TEST CARRIED OUT IN ACCORDANCE WITH  
AS 4586:2013 (Appendix C)

Test Date: 15 May 2018

---

Location: Slip Resistance Laboratory Test conducted by: KH, AG

Sample Fixed

Joint width: 0 mm

Surface structure:  Smooth  
 Profiled  
 Structured

**RESULTS**

	Critical angle mean	Reported mean
<b>Mean angle of inclination:</b>	Verification Board WB-A: 11.82 °	11 °
	Verification Board WB-B: 18.29 °	18 °
	Verification Board WB-C: 23.51 °	23 °
<b>Mean angle of inclination of Test Board:</b>	19.03 °	19 °

**CLASSIFICATION:**

**Quality Group:**

**B**

---



## **Infrastructure Technologies**

Gate 5, 2 Normanby Road Clayton VIC 3168, Australia

Telephone: 61 3 9545 2777 Web: <http://www.csiro.au>

---

REPORT NO: 8089.1  
ISSUE DATE: 22 May 2018  
MANUFACTURER: Armstrong Flooring  
PRODUCT DESC: Accolade Foothold 1 Vinyl Flooring

Page 4 of 4

---

Date and Place 22 May 2018, Clayton, Vic

Name, Title and Signature:

A large, light gray watermark of the CSIRO logo is centered on the page. It features the same stylized bar chart and the word "CSIRO" in a large, bold, sans-serif font.

**ANDY GIANG**  
**Technical Officer**  
Tel: 61 3 95452777  
Email: [Andy.Giang@csiro.au](mailto:Andy.Giang@csiro.au)